

FIRE ALARM FEES & REQUIREMENTS

Maintenance / Repair Fee: \$0.00		
No Fee	Permit Required	IFC- 105.1.5 AHJ
No Fee	NO Plan Review	AHJ, NFPA 72 3.2.2; A3.2.2
	NO Spec Sheet	AHJ, NFPA 72 3.2.2; A3.2.2
	NO Site Inspection	AHJ, NFPA 72 3.2.2; A3.2.2
	Service Tag REQUIRED	IFC- 901.6.3, NFPA 72 – Ch. 7, 7.5.6, 7.8

Modification / Upgrade Fee: \$150.00		
\$50.00	Permit REQUIRED***	IFC- 105.1.1; 105.7; 105.7.7; NFPA 72- 10.19.2
\$50.00	Inspection REQUIRED – This is a Pass/Fail inspection**	AHJ; IFC- 901.2; NFPA 72 7.3, 3.3.228,
\$50.00	Plan Review Required	IFC- 901.2, NFPA 72 – Ch. 7.
	Spec Sheets REQUIRED at time of permit request	IFC- 907.1.3, NFPA 72 – Ch. 7, 7.5.6, 7.8
	Pre-Test Letter REQUIRED	IFC- 901.2.1; 901.5; 907.7, NFPA 72 – Ch. 7, 7.5.6, 7.8
	Installation Certificate REQUIRED	IFC- 901.6.3; NFPA 72 – Ch. 7, 7.5.6, 7.8
	Service Tag REQUIRED	IFC- 901.6.3; NFPA 72 – Ch. 7, 7.5.6, 7.8

NEW Fire Alarm Fee: \$200.00		
\$100.00	Plan Review w/ APS signature REQUIRED*	IFC 901.2; NFPA 72- Ch. 7, 7.4
\$50.00	Permit REQUIRED***	IFC- 105.1.1; 105.7; 105.7.7; NFPA 72- 10.19.2
\$50.00	Final Inspection REQUIRED – This is a pass/fail inspection**	AHJ; IFC 107.2; NFPA 72 Ch. 7, 7.5.2
	Pre-Test Letter REQUIRED	IFC- 901.2.1; 901.5; 907.7; NFPA 72- Ch. 7, 7.5
	Acceptance Test REQUIRED 24 hrs. before FINAL inspection request	IFC- 901.2.1; 901.5; 907.7; NFPA 72-3.3.190.5; Ch. 7; 7.5; 7.3.7; 7.5.2; 14.4.1
	System Record of Completion REQUIRED	IFC- 901.6.3 NFPA 72-Ch. 7; 7.5.6; 7.8
	System properly Tagged REQUIRED	IFC- 901.6.3, NFPA 72-Ch. 7; 7.5.6; 7.8

* Re-inspection plan review- \$100.00

**Re-inspection fee - \$50.00

***Working without permit- 1.5X permit fee and a citation **WILL** be issued.